

**REQUEST FOR INFORMATION
FOR
COUNTY OF SAN MATEO**

**LISTED BELOW ARE THE QUESTIONS (Q) SUBMITTED TO DATE BY
POTENTIAL BIDDERS FOR THE**

RECONSTRUCTION OF LOYOLA AVENUE

**COUNTY PROJECT NO. RW921
PROJECT FILE NO. E5019**

**THE COUNTY OF SAN MATEO DEPARTMENT OF PUBLIC WORKS
HAS PROVIDED RESPONSES (R) TO THE QUESTIONS BELOW**

- Q1. The plans and specifications do not include core data, or pavement structural section thicknesses with underlying soil types. If you don't have core data, as-builts are still helpful. Can you release that information through an addendum?
- R1. We do not have core data or as-builts for Loyola Ave. Pothole data at locations shown on the plans shows varying AC depths (3" to 5") with no AB. For the underlying soil type, sandy clay and clayey sand were identified by soil testing lab. No addendum will be issued.*

All inquiries/Request for Information (RFI) shall be submitted in writing to azhang@smcgov.org, not less than five (5) working days prior to bid opening.