

Camille Leung

From: Scott Fitinghoff <sfitinghoff@cornerstoneearth.com>
Sent: Friday, July 10, 2020 1:44 PM
To: Camille Leung
Cc: Amy Ow; Noel Chamberlain
Subject: RE: Asbestos

CAUTION: This email originated from outside of San Mateo County. Unless you recognize the sender's email address and know the content is safe, do not click links, open attachments or reply.

Hi Camille,

My Field engineer, Engineering Geologist, and I have been making visits to the site to observe the exposed soil and bedrock during construction for Lots 9 and 10, Lot 11 has not started yet. We have observed some expansive soils on the lower part Lot 9 and the fill between Lots 9 and 10 as anticipated in our report. Lot 10 has been mostly low PI soils over sandstone bedrock. The expansive soil has been handled as recommended in our geotechnical report. I trust this provides the information you need at this time.

Scott

Sincerely,

Scott E. Fitinghoff, P.E., G.E.
Principal Engineer
408-747-7503 (cell)



1259 Oakmead Parkway
Sunnyvale | California 94085
T 408-245-4600 Ext. 103 | F 408-245-4620

During the Covid-19 event, I will be working mostly remotely. Please use my cell phone number 408-747-7503, when calling. Thank You.

From: Camille Leung <cleung@smcgov.org>
Sent: Friday, July 10, 2020 1:04 PM
To: Scott Fitinghoff <sfitinghoff@cornerstoneearth.com>
Cc: Amy Ow <aow@smcgov.org>
Subject: FW: Asbestos

Hi Scott,

Also, please provide an update on:

Mitigation Measure GEO-5: During site grading, soils in each lot shall be observed and tested by the project Geotechnical Engineer to determine if expansive soils are exposed.

Thanks!

From: Camille Leung

Sent: Friday, July 10, 2020 12:13 PM

To: 'sfitinghoff@cornerstoneearth.com' <sfitinghoff@cornerstoneearth.com>

Cc: Amy Ow <aow@smcgov.org>

Subject: Asbestos

Hi Scott,

Please provide an update on the sampling recommended in the attached report.

Thanks